

# Memo

**To:** City Council

**From:** Gary Hartwell

**CC:** Henry Hill

**Date:** January 11, 2010

**Re:** Monthly Report for December, 2009

We recorded 2.6 inches of rainfall in December and used 386.6 million gallons of water for the month. Our average usage was 12.5 million gallons per day (mgd) or about 115.6 gallons per person per day (gpcd). Our daily water usage ranged from a minimum of 6.6 mgd (61 gpcd) on December 2 to a maximum of 17.5 mgd (162 gpcd) on December 22. For the entire year, we recorded about 41.8 inches of rainfall and averaged about 202 gpcd. The December bacteriological and disinfectant by-product samples all tested negative for contamination. All of our chlorine samples tested within the normal limits for water quality.

We installed about 92 water meters in December and we televised about 86 private service lines for new homes.

We inspected about 1627 fire hydrants and about 110 manholes for proper operation. We repaired 11 sidewalks and installed about 92 traffic signs.

We used about 19,957 gallons of unleaded fuel and about 6,934 gallons of diesel fuel in the month of December.

We collected about 2,580 residential tons and about 2,635 tons of commercial solid waste in November. Curbside recycling was about 990 tons in November.